



Jim Doyle, Governor  
Jack L. Fischer, A.I.A., Secretary

December 4, 2007

HUFFCUTT CONCRETE, INC.  
BILL OLSON  
4154 123RD ST  
CHIPPEWA FALLS WI 54729

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: HUFFCUTT CONCRETE, INC.  
Product Name: MICROFAST 0.5/PUMP1250/750  
Model Number(s): 1250/750 PUMP [L.L. 41 IN., 17.1 GAL/IN.]  
Product File No: 20070525

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of December 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 500 gallons per day.
- This product must be sized based on daily wastewater flow (gallons per day). The gallons per day value must be at least 150 gallons per day per bedroom.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- A Best GF10-8 effluent filter or equivalent shall be installed in this system.

MICRO FAST 0.5 UNIT RATED FOR MAX. 500 GPD

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov